



**SNOHOMISH**  
**HEALTH DISTRICT**  
WWW.SNOHD.ORG

Environmental Health Division

**Date:** March 28, 2022

**To:** Christine Phillips  
2106 Pacific Avenue, Suite 300  
Tacoma, WA 98402

**From:** Antonia Weiss  
Environmental Health Division  
Snohomish Health District

**Subject:** Land Use Review – 22 102230CUP  
RTFN – Residential Treatment Facility North  
Property Tax Acct. Number: 320418 001 00100

SHD has no objections to the proposed Conditional Use Permit for the civil behavioral health services buildings with the following conditions:

Prior to building permit issuance an application for an on-site sewage disposal system permit must be approved and the proposed Group A public water system must obtain approval from the Washington State Department of Health, Northwest Drinking Water Operations.

In addition, if the proposed sewage effluent daily flows exceed three thousand five hundred gallons per day from the proposed and existing buildings the on-site sewage system must obtain approval from the Washington State Department of Health Large On-site Sewage System (LOSS) Program.

AW:rf

CC: Rebecca Samy, Snohomish County Planning and Development Services